



Certificate No.:

**0845 – CPD–CX10108**

### **EC-CERTIFICATE OF CONFORMITY**

Issued by Danish Institute of Fire and Security Technology. Notified body No. 0845

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

#### **Trumpf, Texture, Morse Code, Black Squares and Modern Squares**

for application as flooring

**placed on the market by**

Fletco Tæpper A/S  
Mads Clausensvej 2  
DK-7430 Ikast

and produced in the factory

Ikast

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body Danish Institute of Fire and Security Technology (*Dansk Brand- og sikringsteknisk Institut*) has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all the provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

#### **EN 14041 (2004/AC): Resilient, textile and laminate floor coverings – Essential characteristics**

were applied and that the product fulfils the below mentioned requirements:

**Reaction to fire      Class C<sub>fl</sub>-s1**

The attached 2 annexes forms part of this certificate.

This certificate was first issued on **2008-06-19** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

(The certificate supersedes the previous version of this certificate, issued 2007-01-30.)

*Tom Nisted*

Tom Nisted

*Henning Albøge*

Henning Albøge

#### **Danish Institute of Fire and Security Technology**

Jernholmen 12, DK-2650 Hvidovre  
Phone: +45 36 34 90 00, Fax: +45 36 34 90 01  
E-mail: dbi@dbi-net.dk  
www.dbi-net.dk

The certificate should only be reproduced in  
extenso  
- in extracts only with a written agreement with

# **EXTENT**

<b>Type</b>	<b>Description</b>
<p>Trumpf, Texture, Morse Code, Black Squares and Modern Squares</p> <p>Field of application</p>	<p>Tufted carpet with loop pile.</p> <p>Pile: 100 % polyamide, 410 to 700 g/m<sup>2</sup></p> <p>Rear side: textile</p> <p>Total height: 4.5 to 6.0 mm</p> <p>Pile height: 2.5 to 4.0 mm</p> <p>Total weight: 1100 to 1850 g/m<sup>2</sup></p> <p>The carpet is to be adhered to a substrate of Euroclasses A1<sub>f1</sub> or A2<sub>f1</sub> at least 6 mm thick and with density equal to or greater than 1350 kg/m<sup>3</sup> with a acrylate-copolymer dispersion glue; application rate: 350 to 450 g/m<sup>3</sup> (wet).</p>

**TEST DOCUMENTATION**

Accredited Laboratory	Report no.	Date
DBI	PF12863c PF12863a PF12863d	2008-04-25 2008-04-25 2008-04-28
DBI	PC10177a	2008-04-29

**TECHNICAL BASIS**

Designation	Identification	Date
Produkt specification Trumpf, Texture, Morse Code, Black Squares and Modern Squares		2008-05-19
Supplementary information		2007-01-25